



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	2/22/08	Interpretation	07-161
Topic	Area Increase for Side Yards		
Code Section(s)	CBC Section 506		
Requested by	Syrus Mobayen CK Architect 302 W. Foothill Blvd. Monrovia, CA 91016 (626) 357-9880 syrus@charch.net		

I am using fire sprinklers to increase the number of stories (CBC Section 506); can I still obtain an area increase for side yards?

Yes, where you have adequate side yards in accordance with 2001 CBC Section 505.